



TOWN OF
NEW LONDON, NEW HAMPSHIRE

375 MAIN STREET • NEW LONDON, NH 03257 • WWW.NL-NH.COM

NOTICE OF DECISION
New London Planning Board

RE: CONDEROSA TRUST STORMWATER MANAGEMENT PLAN APPROVAL DECEMBER 8, 2010

MAP 068, LOT 004-000

You are hereby notified that on this date, the New London Planning Board reviewed a request by Charlie Hirschberg of CLD Consulting Engineers, representing the Conderosa Trust, Jean & John Connolly Trustees, to approve a stormwater management plan for the subject lot in order to permit impervious surfaces totaling over 20%. If approved, the plan results in a total of 26.7% impervious surface on the lot, within the 250' shoreland zone. Stormwater runoff calculations were provided with the application demonstrating that the post-development stormwater runoff did not exceed the pre-development runoff volume or rate.

After hearing testimony regarding the proposed stormwater management plan, **with one dissenting vote, the New London Planning Board APPROVED the applicant's stormwater management plan.**

Tom Cottrill, Chairman

Board of Selectmen P: 603-526-4821 x 10 F: 603-526-9494	Town Administrator P: 603-526-4821 x 13 F: 603-526-9494	Town Clerk-Tax Collector P: 603-526-4821 x 11 F: 603-526-9494	Finance P: 603-526-4821 x 21 F: 603-526-9494	Assessing P: 603-526-4821 x 20 F: 603-526-9494
Planning/Zoning P: 603-526-4821 x 16 F: 603-526-9494	Fire Department P: 603-526-6073 F: 603-526-6079	Police Department P: 603-526-2626 F: 603-526-2782	Public Works P: 603-526-6337 F: 603-526-9662	Recreation P: 603-526-4821 x 14 F: 603-526-9494